THERMOLEC

MANUFACTURER PRODUCT ATTESTATION

ISSUED BY	**THERMOLEC LTEE/LTD** **2060 LUCIEN-THIMENS** **ST LAURENT, QC H4R 1L1** **CANADA**
This is to certify that	POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS
representative samples of	Power Monitor Panels, Series DCC-12
has met the Standard(s) for Safety	UL 508-2018 & CSA C22.2 No. 14-18, Industrial Control Equipment
and is designed for	any type of resistive load up to 100A (80A continuous) and any type of inductive load up to 50A (40A continuous)

Signature

Date 2025/08/01

Daniel Menassa
Vice President, Thermolec Ltée./Ltd.